

LOCATION 114 W. HARRISON Ave CITY CAST.  
BETWEEN Logan St. STREET & N. Falls St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>14'</u>			<u>9-11-96</u>
MAIN TO PROP. LINE	<u>1"</u>	<u>"</u>	<u>2'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>"</u>	<u>12'</u>			

ENTERS: Same BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 48' West from @ of Logan St.

PRESSURE TEST: @ 100 PSI FOR 4 HRS. BY MP  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 96  
DEPTH: 3 FT. 0 IN. LOCATION West side of 114 W. Harrison Ave

"A" P/S READING P TOTAL ANODES 1# 17# L.R. # \_\_\_\_\_

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY