

LOCATION 118 W. HARRISON AVE CITY GAST.

BETWEEN Logan St. STREET & N. Falls St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>86'</u>			<u>9-11-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>32'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>54'</u>			

ENTERS: Same BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 72' East from @ of Falls Ave.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY me

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION Southside of W. Harrison Ave

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY