

LOCATION 134 Harrison DR CITY GASTONIA

BETWEEN Crest DR. STREET & S New Hope Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>167'</u>	<u>8-14-96</u>		
MAIN TO PROP. LINE	<u>3/4'</u>	<u>P</u>	<u>15'</u>			
PROP. LINE TO BLDG.	<u>3/4'</u>	<u>P</u>	<u>150'</u>			

ENTERS: 134 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 300' W. of center of

Crest Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hufstetler

MAIN-SIZE 2' C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 FT. 0 IN. LOCATION 13' S. of center of Harrison DR.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 429416

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY