

LOCATION 402 W. HARRISON AVE CITY CAS.
BETWEEN N. YORK ST. STREET & Hwy 321 STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>53'</u>			<u>12-16-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>48'</u>			


ENTERS: Same BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 257' from @ of Hwy 321

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY ml
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 FT. 0 IN. LOCATION NORTHSIDE of W. HARRISON AVE

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R.# —

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>		
	P/S Pipeline Lead - White Existing Main	<u>E</u>		