

LOCATION 407 W. HARRISON AVE CITY CASST
BETWEEN N. YAK ST. STREET & Hwy 321 STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>81'</u>		<u>12-18-96</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>25'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>56'</u>			


ENTERS: SAME BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 197' from @ of N 321

PRESSURE TEST: @ 100 PSI FOR 4 HRS. BY JM
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 93

DEPTH: 3 FT. 0 IN. LOCATION NORTH SIDE OF W. HARRISON AVE

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY