

LOCATION 412 W. HARRISON Ave CITY CRIST

BETWEEN Hwy 321 STREET & N. York St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>47'</u>		<u>12-18-96</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>2'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>45'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 120' from @ of Hwy 321


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JW

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 FT. 0 IN. LOCATION North Side of W. Harrison Ave

"A" P/S READING P TOTAL ANODES 1# 17# ✓ L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY