

LOCATION 2150 Hartford DRCITY CASTONIABETWEEN FoxworthSTREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P/astic</u>	<u>95'</u>	<u>12/23/92</u>		
MAIN TO PROP. LINE	<u>3/4"</u>		<u>45'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>50'</u>			

ENTERS: 2150


BRANCHED INTO:

TAP SIZE: 3/8"PRESSURE 60 PSI

INCHES W.C.

LOCATION South side of 2150PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DTMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1972DEPTH: 3 FT. 0 IN. LOCATION West side of Hartford"A" P/S READING 1.40 TOTAL ANODES 1# 0 17# 0 L.R. # 2322828

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY