

LOCATION 2443 + 2451 Hawk Ridge Dr. CITY GASTONIA
BETWEEN Neal Hawkins Rd. STREET & Talon Ct. STREET

	SIZE	TYPE	2443 LENGTH	2451	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>60'</u>	<u>40'</u>	<u>2-18-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>10'</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>50'</u>	<u>35'</u>			

ENTERS: 2443 Hawk Ridge Dr. BRANCHED INTO: 2451 Hawk Ridge Dr.
TAP SIZE: 1/2" ON 2443 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 70' S of Cor Talon Ct.
3/4 3-way P-Tee on 2451


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2" C.I.: _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 20' W of Cor Hawk Ridge Dr.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 00105870

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser's</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY