

LOCATION 2490 Hawk Ridge Dr. CITY Gastonia
BETWEEN Neat Hawkins Rd. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>101'</u>	<u>6-17-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>56'</u>			

ENTERS: 2490 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 189' N. of center of


Neat Hawkins Rd
PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hunkeler

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 19' W. of center of Hawk Ridge Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 384804

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		