

LOCATION 2491 Hawk Ridge Dr CITY GASTONIA

BETWEEN Neal Hawkins Rd STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>70'</u>	<u>8-11-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>65'</u>			

ENTERS: 2491 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 195' N. of center of Neal Hawkins Rd


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. of W. 8th St.

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 19' W. of center of Hawk Ridge Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 517586

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY