

LOCATION 2499 Hawk Ridge Dr. CITY CASSTONIA

BETWEEN Neal Hawkins Rd. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>53'</u>	<u>6-12-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>48'</u>			

ENTERS: 2499 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 74' W. of center of

Hawk Ridge Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. HUFFGUTH

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1986

DEPTH: 3 FT. 0 IN. LOCATION 29' N. of center of Neal Hawkins Rd.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 384806

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY