

LOCATION 504 Hawthorne Lane CITY GASTONIA
BETWEEN Fair Field Dr. STREET & Fair Field Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>0'</u>	<u>6-4-94</u>	<u>Tied over 129'</u>	<u>9-11-92</u>
MAIN TO PROP. LINE					<u>Existing 3/4</u>	
PROP. LINE TO BLDG.					<u>Plastic</u>	

ENTERS: 504 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 100 P.S.I. _____ INCHES W.C. LOCATION 238' S of C of Fairfield Dr.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993


DEPTH: 3 Ft. 0 In. LOCATION 16' E of C of Hawthorne Dr.

"A" P/S READING Plastic TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS: Tied over Existing 3/4 Plastic Service to New - 2" Plexco Plastic GAS MAIN

Bare Main Replacement

Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY