

LOCATION 506 Hawthorne Lane

CITY GASTONIA

BETWEEN Fair Field Dr.

STREET & Fair Field Dr.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	3'	12-20-68 orig.	Tied over	93' Existing
MAIN TO PROP. LINE				Tied over 6-4-94	3/4 (SW) to	New 3" Alexco
PROP. LINE TO BLDG.					Plastic	Main.

ENTERS: 506

BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 340' S of C of Fair Field Dr.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 in. LOCATION 16' E of C of Hawthorne Lane.

"A" P/S READING Plastic TOTAL ANODES 1* 17* L.R. #

REMARKS: Bare Main Replacement Program Tied Tracer wire off at Tee. Bonded Dresser. Retired 1/4 Bare Main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser 190
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY