

LOCATION 508 Hawthorne Lane CITY GASTONIA
BETWEEN Fair Field Dr. STREET & 510 Hawthorne Lane STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------|-----------|-------------------------|-------------------------|----------------|
| MAIN TO BLDG. | <u>3/4</u> | <u>P</u> | <u>0'</u> | <u>Tied over 6-4-94</u> | <u>Tied over</u> | <u>6-25-87</u> |
| MAIN TO PROP. LINE | | | | | <u>78' Existing 3/4</u> | |
| PROP. LINE TO BLDG. | | | | | <u>Plastic</u> | |

ENTERS: 508 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 354' S of C of Fair Field Dr.

PRESSURE TEST: @ 100 psi For 14 Hrs. By RL


MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 in. LOCATION 16' E of C of Hawthorne Lane.

"A" P/S READING Plastic TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Tied over Existing 3/4 Plastic Service to new 2" Plexco Plastic Gas Main.

Retired Existing 1/4 Bare Main Bare Main Replacement Program



| Test Station | | | ENG. DEPT. USE ONLY |
|--|------|-----------------------|---------------------|
| Reading & Location | Lead | Volts | |
| P/S Pipeline Lead - Red New Service | S | <u>Rise 1 Plastic</u> | |
| P/S Pipeline Lead - White Existing Main | E | | |