

LOCATION 524 Hawthorne CITY Lathrop
BETWEEN Fairfield Dr. STREET & Fairfield Dr. STREET

	SIZE	TYPE	P	LENGTH	S	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>		<u>5</u>	<u>116</u>		<u>Tied over</u> <u>6-4-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>		<u>5</u>	<u>0</u>				
PROP. LINE TO BLDG.	<u>3/4</u>		<u>0</u>	<u>116</u>				

ENTERS: 524 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Inside of house

PRESSURE TEST: @ 100 psi For 1 1/2 Hrs. By Spencer

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 2 Ft. 6 In. LOCATION 20' E of apt


"A" P/S READING 1.20 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Ins. dresser was bombed

~~Bare~~ Main Replacement
Program

~~Bare~~ Main Replacement
Program

~~Bare~~ Main Replacement
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY