

LOCATION 1746 Haynes St. APT. # A & B CITY Gastonia  
BETWEEN Webb st STREET & Bessemer city STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	314	P	83'	10-28-95		
MAIN TO PROP. LINE	11	11	33'			
PROP. LINE TO BLDG.	11	11	50'			

ENTERS: 1746 BRANCHED INTO: ①  
TAP SIZE: 5/8 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 631' E of C of Webb st

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BC  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1961  
DEPTH: 3 Ft. \_\_\_\_\_ In. LOCATION 14' S of C of Haynes

"A" P/S READING 1.2 TOTAL ANODES 1\* - 17\* \_\_\_\_\_ L.R. # 554902

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY