

LOCATION 3553 Heather Ln. CITY GASTONIA
BETWEEN Union Rd. STREET & Robinson Rd. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>108'</u>	<u>1-20-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>48'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>60'</u>			

ENTERS: 3553 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 745' SE of Cof Wren Rd.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1982
DEPTH: 3 FT. 6 IN. LOCATION 16' S of Cof Heather Ln.

"A" P/S READING Plastic n/a TOTAL ANODES 1# 0 17# 0 L.R. # 015014

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Rise Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY