

LOCATION 3561 HEATHER LN

CITY GASTONIA

BETWEEN WREN RD

STREET &amp; HEATHER LN

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	PLASTIC	137'	2-25-98		
MAIN TO PROP. LINE	3/4	PLASTIC	41'			
PROP. LINE TO BLDG.	3/4	PLASTIC	96'			

ENTERS: 3561

BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 PSI 0 INCHES W.C. LOCATION 704' W of Lot WREN RD


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1983

DEPTH: 3' FT. 0 IN. LOCATION 17' S of Lot HEATHER LN.

"A" P/S READING PLASTIC TOTAL ANODES 1# 0 17# 0 L.R. # 0117994

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	PLASTIC
P/S Pipeline Lead - White Existing Main	E	Rise

ENG. DEPT. USE ONLY