

LOCATION 1221 Heatherloch Dr CITY GASTONIA

BETWEEN DORNOCK DR. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>117'</u>	<u>8-1-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>7'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>110'</u>			

ENTERS: 1221 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 263' W. of center of DORNOCK DR.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. HUCKLEBERRY

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1973

DEPTH: 3 FT. 0 IN. LOCATION 20' S. of center of Heatherloch Dr.

"A" P/S READING 1.0 TOTAL ANODES 1# 0 17# 0 L.R. # 496989

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY