

LOCATION 2341 Heathstone Dr CITY Gastonia

BETWEEN Aracoma Dr STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>130'</u>	<u>9.30-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>125'</u>			

ENTERS 2341 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES WC LOCATION 595' NE. of center of Aracoma Dr

PRESSURE TEST @ 160 PSI FOR 44 HRS BY S.A.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2007

DEPTH 3 FT 0 IN LOCATION 46' SE. of center of Heathstone Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 288103

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

