

LOCATION 4209 Heatherstone Dr CITY CASLETON

BETWEEN Union Rd. STREET & Frostwood Dr STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	108'	6-24-97		
MAIN TO PROP. LINE	3/4"	P	35'			
PROP. LINE TO BLDG.	3/4"	P	78'			

ENTERS: 4209 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 301' W. of center of

Union Rd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Chubb & R. Kelly

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1990

DEPTH: 3 FT. 0 IN. LOCATION 16' S. of center of Heatherstone Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 372043

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY