

LOCATION 4233 Heather Stone Dr. CITY BASTONIA
BETWEEN Frostwood Dr. STREET & Union Rd. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>119'</u>	<u>4-24-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>42'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>77'</u>			

ENTERS: 4233 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 35' E of Frostwood Dr.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1982
DEPTH: 3 FT. 0 IN. LOCATION 20' S of Heather Stone Dr.

"A" P/S READING PLASTIC N/A TOTAL ANODES 1# 0 17# 0 L.R. # 275289

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>PLASTIC</u>

ENG. DEPT. USE ONLY