

LOCATION 622 Heathwood Ct CITY GASTONIA
BETWEEN Baronwood Ct STREET & myrtlewoods Ct STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4'	Plastic	128'	9/14/96		
MAIN TO PROP. LINE	3/4"		42'			
PROP. LINE TO BLDG.	3/4"		86'			

ENTERS: 622 BRANCHED INTO:
TAP SIZE: 1/2" PRESSURE 60 PSI _____ INCHES W.C. LOCATION South side of 622


PRESSURE TEST: @ 100 PSI FOR 4 HRS. BY DT

MAIN-SIZE 2' C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 FT. 0 IN. LOCATION West side of Heathwood Ct

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 494644

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY