

LOCATION 625 HEATHWOOD CT CITY GASTONIA

BETWEEN MYRTLE WOODS DR STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>58'</u>	<u>7-3-97</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>8'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>50'</u>			

ENTERS: 625 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 40' N OF C OF MYRTLE WOODS DR


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SA

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1994

DEPTH: 3 FT. 6 IN. LOCATION 22' W OF C OF HEATHWOOD CT

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ I.R. # 00420958

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY