

LOCATION 630 Heathwood dr CITY Gastonia  
BETWEEN Myrtlewood STREET & 5th St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>103'</u>	<u>8-11-98</u>		
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>48'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>55'</u>			

ENTERS: 630 BRANCHED INTO: —

TAP SIZE: 1/2 PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W.C. LOCATION 23' w. of cor  
Heathwood


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JP

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION \_\_\_\_\_

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<u>ER</u>	<u>P</u>
	P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY