

LOCATION 2029 Helen Dr. CITY East.

BETWEEN Audrey STREET & PAMELA STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	$\frac{3}{4}$ "	<u>?</u>	<u>187'</u>			<u>6-27-97</u>
MAIN TO PROP. LINE	"	"	<u>42</u>			
PROP. LINE TO BLDG.	"	"	<u>145'</u>			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: $\frac{3}{4}$ " PRESSURE 60 PSI _____ INCHES W.C. LOCATION 281' from @ of

Audrey


PRESSURE TEST: @ 100 PSI FOR $\frac{1}{4}$ HRS. BY DF

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION South Side of Helen

"A" P/S READING ? TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY