

LOCATION 1906 E Hemlock St

CITY Gastonia

BETWEEN Grover

STREET & Ida

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	72'	2-5-96		
MAIN TO PROP. LINE	3/4	P	10'			
PROP. LINE TO BLDG.	3/4	P	62'			

ENTERS: 1906

BRANCHED INTO: —

TAP SIZE: 3/8

PRESSURE 60 P.S.I. _____ INCHES W.C.

LOCATION 12' N OF

Hemlock

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By M Parker

MAIN-SIZE 1 1/2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1955


DEPTH: 3 Ft. 0 In. LOCATION 208' E OF Grover

"A" P/S READING .9

TOTAL ANODES 1# _____ 17# _____

L.R. # 48954

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P-riser
P/S Pipeline Lead - White Existing Main	E	