

LOCATION 1908 C. Hemlock St.

CITY GASTONIA

BETWEEN GROVER ST.

STREET & IDA ST.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	45'	1-20-96		
MAIN TO PROP. LINE	1"	"	8'			
PROP. LINE TO BLDG.	1"	"	37'			

ENTERS: 1908

BRANCHED INTO:

TAP SIZE: 1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 11' N. of C of

Hemlock St.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By AP

MAIN-SIZE 1 1/2 C.I. — BARE STEEL — COATED STEEL ☒ PLASTIC — YEAR INSTALLED 1955

DEPTH: 2 Ft. 0 In.


LOCATION

"A" P/S READING 70

TOTAL ANODES 1# — 17# 1

L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	R	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY