

LOCATION 2107 Hemlock St.CITY GastoniaBETWEEN Ida St.STREET & Dead End

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>108'</u>	<u>11-14-94</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>27'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>81'</u>			

ENTERS: 2107BRANCHED INTO: —TAP SIZE: 1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 12' N. of C of  
Hemlock St.PRESSURE TEST: @ 100 psi

For

1/2 Hrs.

By

JPMAIN-SIZE 2"C.I. —BARE STEEL —COATED STEEL ✓PLASTIC —YEAR INSTALLED 1956DEPTH: 3

Ft.

0

In.

LOCATION

"A" P/S READING


.80

TOTAL ANODES 1\*

17\*

L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY