

LOCATION

706 Henry Ave.

CITY

East

BETWEEN

Pryor

STREET &

Dead End

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	68'		4 - 10	- 96
MAIN TO PROP. LINE	1"	"	20'			
PROP. LINE TO BLDG.	1"	"	48'			

ENTERS:

706 Henry Ave.

BRANCHED INTO:

TAP SIZE:

1/2"

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

N. of 706

PRESSURE TEST:

@

100

psi

For

1 1/4

Hrs.

By

G.K.

MAIN-SIZE

2

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

96

DEPTH:

3

Ft.

In.

LOCATION

S. Side of Henry Ave.

"A" P/S READING


P

TOTAL ANODES 1*

17*

L.R. #

REMARKS:



Test Station

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New Service

S

P

P/S Pipeline Lead - White
Existing Main

E

ENG. DEPT. USE ONLY