

LOCATION

709 Henry Ave.

CITY

East

BETWEEN

PRUP

STREET &

Dead End

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	52'		4-11-96	
MAIN TO PROP. LINE	"	"	4'			
PROP. LINE TO BLDG.	"	"	48'			

ENTERS:

709 Henry Ave.

BRANCHED INTO:

TAP SIZE:

1/2

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

E. side of 709

PRESSURE TEST:

@

100

psi

For

1 1/4

Hrs.

By

GK

MAIN-SIZE

2

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

96

DEPTH:

3

Ft.

In.

LOCATION

S. side of Henry Ave.

"A" P/S READING


P

TOTAL ANODES 1#

17#

L.R. #

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New Service

S

P

P/S Pipeline Lead - White
Existing Main

E