

LOCATION 711 HENRY AVE CITY GAST.  
BETWEEN PRYOR STREET & DEAD END STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	45'		4 - 11	-96
MAIN TO PROP. LINE	"	"	4'			
PROP. LINE TO BLDG.	"	"	41'			

ENTERS: 711 Henry Ave BRANCHED INTO:  
TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION E. side of 711

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By GL  
MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 96  
DEPTH: 3 Ft. \_\_\_\_\_ In. LOCATION S. side of Henry Ave.

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	7
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY