

LOCATION 2936 Heritage Commons Ln. CITY Gastonia
BETWEEN Kennett Ave. STREET & Cat-De-Sac STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	26'	3-14-00		
MAIN TO PROP LINE	3/4"	P	6'			
PROP LINE TO BLDG	3/4"	P	20'			

ENTERS: 2936 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W C LOCATION 89' E. of center of Heritage Commons Ln.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S.H.
MAIN SIZE 3/4" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000
DEPTH: 2 FT 0 IN LOCATION 38' N. of center of Kennett Ave.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 211662

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	