

LOCATION 2948 Heritage Commons Ln. CITY CANTONIA  
BETWEEN Kennett Ave. STREET & Cul-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>114'</u>	<u>2-26-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>50'</u>			
PROP. LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>64'</u>			

ENTERS 2948 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 438' W. of center of Kennett Ave


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S. G.

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED \_\_\_\_\_

DEPTH 3 FT 0 IN LOCATION 19' W. of center of Heritage Commons Ln.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # \_\_\_\_\_

REMARKS  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	