

LOCATION 2954 Heritage Commons Ln CITY Castonville
BETWEEN Kennett STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>104'</u>	<u>9-199</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>40'</u>			
PROP. LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>64'</u>			

ENTERS: 2954 BRANCHED INTO 0
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY EP

MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1998

DEPTH 3 FT 0 IN LOCATION _____

"A" P/S READING P TOTAL ANODES 1# 17 L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	