

LOCATION 2958 Heritage Commons CITY Gastonia

BETWEEN Kennett Ave STREET & _____ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>77'</u>	<u>2-9-00</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>78'</u>			

ENTERS. 2958 BRANCHED INTO: _____

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 93' N. of center of Kennett Ave


PRESSURE TEST @ 100 PSI FOR 4 HRS BY S.H.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED _____

DEPTH: 3 FT 0 IN LOCATION 20' W. of center of Heritage Commons

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 97133

REMARKS.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	