

LOCATION 2973 Heritage Commons Ln. CITY Gastonia  
BETWEEN Kenneth Ave. STREET & Hoffman Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>80'</u>	<u>7-12-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>4'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>76'</u>	<u>"</u>		

ENTERS 2973 BRANCHED INTO 0  
TAP SIZE 1/2" PRESSURE 60 PSI \_\_\_\_\_ INCHES WC LOCATION 220' north


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY center of Kenneth Ave.  
D. Woody

MAIN SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 3' FT 0" IN LOCATION 20' west of center of Heritage Commons Ln.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # C 000 3360

REMARKS New 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>