

LOCATION 2990 Heritage Commons Ln CITY Gastonia

BETWEEN Kerritt Ave STREET & Hoffman Rd. STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|-------------------|-------------|----------|-------------|----------------|---------|---------|
| MAIN TO BLDG | <u>3/4"</u> | <u>P</u> | <u>132'</u> | <u>7-28-60</u> | | |
| MAIN TO PROP LINE | <u>3/4"</u> | <u>P</u> | <u>60'</u> | | | |
| PROP LINE TO BLDG | <u>3/4"</u> | <u>P</u> | <u>72'</u> | | | |

ENTERS 2990 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 20' S. of center of Kerritt Ave

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S. G.

MAIN-SIZE 2" C I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1999

DEPTH 3 FT 0 IN LOCATION 30' W. of center of Heritage Commons Ln

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L R # 656821

REMARKS

