

LOCATION 2991 Heritage Commons Ln CITY Cincinnati
BETWEEN Kennett Ave STREET & Elde Cr STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3 1/4"</u>	<u>P</u>	<u>70'</u>	<u>3-9-00</u>		
MAIN TO PROP LINE	<u>3 1/4"</u>	<u>P</u>	<u>40'</u>			
PROP. LINE TO BLDG	<u>3 1/4"</u>	<u>P</u>	<u>30'</u>			

ENTERS: 2991 BRANCHED INTO:

TAP SIZE: 3 1/4" PRESSURE 60 PSI INCHES W.C. LOCATION 119' W. of center of
Heritage Commons Ln

PRESSURE TEST @ 100 PSI FOR 4 HRS. BY S.H.

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED

DEPTH: 3 FT. 0 IN. LOCATION 19' S. of center of Kennett Ave

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 179925

REMARKS:

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

