

LOCATION 2996 Heritage Commons Ln CITY Gastonia  
BETWEEN Hoffman Rd STREET & Kennett Ave STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>110'</u>	<u>11/14/000</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>60'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>50'</u>	<u>"</u>		

ENTERS 2996 Heritage Commons BRANCHED INTO Ø  
TAP SIZE 1/2" PRESSURE 60 PSI INCHES W C LOCATION 62' south of center of Kennett Ave.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Wood

MAIN-SIZE 2" C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 2' FT 6" IN LOCATION 35 Ft West of center of Heritage Commons

"A" P/S READING N/A TOTAL ANODES 1# Ø 17# Ø I.R. # 01003134

REMARKS new plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>