

LOCATION 716 Hickory CT CITY GASTONIA
BETWEEN OAKWOOD CR STREET & MONTANA DR STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8</u>	<u>P</u>	<u>114'</u>	<u>12-4-01</u>		
MAIN TO PROP LINE	<u>5/8</u>	<u>P</u>	<u>15'</u>			
PROP LINE TO BLDG	<u>5/8</u>	<u>P</u>	<u>99'</u>			

ENTERS 716 BRANCHED INTO C
TAP SIZE 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 417' S OF C OF
OAKWOOD CR

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY R.R
MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1997

DEPTH 3 FT 0 IN LOCATION 3' W OF C OF Hickory CT

"A" P/S READING plastic TOTAL ANODES 1# 0 17# 0 LR # 00130224

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u> <u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

