

LOCATION 207 & 209 W. Highland CITY Cosetonia
BETWEEN Airline STREET & Rankin STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>11'</u>	<u>Relocated 4-1-88</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 209 BRANCHED INTO: 207

TAP SIZE: 3/4 50v. PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 PSI FOR 64 HRS. BY ED

MAIN SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED _____

DEPTH: 1 FT. 6 IN. LOCATION _____

"A" P/S READING D TOTAL ANODES 1# 17 # _____ L.R. # _____

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S	0.9375	
	P/S Pipeline Lead - White Existing Main	E		