

LOCATION 207 & 209 N. HIGHLAND ST. CITY East.
BETWEEN Airline STREET & Rankin STREET

	SIZE	TYPE	207 LENGTH	209	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	35'	5'		5-3	96
MAIN TO PROP. LINE	"	"	5'	0			
PROP. LINE TO BLDG.	"	"	30'	5'			


ENTERS: 207 N. Highland BRANCHED INTO: 209 N. Highland
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION N. of 207
5. " 209

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY GLK
MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 96

DEPTH: 3 FT. _____ IN. LOCATION West side of N. Highland

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	7
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY