

LOCATION 215 N HighlandCITY GASBOROBETWEEN AIRLINESTREET & RANKIN

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>93' TIED</u>	<u>TIED OVER</u>		
MAIN TO PROP. LINE			<u>OVER</u>	<u>7-3-96</u>		
PROP. LINE TO BLDG.						

ENTERS: 215

BRANCHED INTO:

TAP SIZE: 3/4

PRESSURE


60

P.S.I.

INCHES W.C.

LOCATION 12' W OFHighlandPRESSURE TEST: @ 100 psi For 1/2 Hrs. By M PALERMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC X YEAR INSTALLED 96DEPTH: 3 Ft. 0 In. LOCATION 358' N OF AIRLINE"A" P/S READING: P TOTAL ANODES 1* 17* L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>P-riser</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY