

LOCATION 218 N Highland St CITY Coastal
BETWEEN RANKIN STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>182</u>	<u>9-24-02</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>50</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>132</u>			

ENTERS 218 BRANCHED INTO 0
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY EP

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1996

DEPTH 3 FT 6 IN LOCATION

"A" P/S READING P TOTAL ANODES 1# 17# LR # _____

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

