

LOCATION 223 N. Highland St. CITY East  
BETWEEN AIRLINE STREET & RANKIN STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>132'</u>		<u>5.8</u>	<u>196</u>
MAIN TO PROP. LINE	<u>1"</u>	<u>S</u>	<u>8'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>S</u>	<u>124'</u>			

ENTERS: 223 N. Highland BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION W. side of 223


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY GK

MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED 96

DEPTH: 3 FT. IN. LOCATION W. side of N. Highland

"A" P/S READING 7 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY