

LOCATION 612 & 614 N. Highland St. CITY Gast.
BETWEEN DAVIDSON STREET & MANNEY STREET

	SIZE	TYPE	614 LENGTH	612 LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	120'	38'		5 - 22	- 96
MAIN TO PROP. LINE	"	"	46'	0			
PROP. LINE TO BLDG.	"	"	80'	38'			

ENTERS: 614 BRANCHED INTO: 612

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION E. of 614
N. " 612


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY GK

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 96

DEPTH: 3 FT. IN. LOCATION west side of N. Highland

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY