

LOCATION 622 N. Highland CITY GAST.

BETWEEN DAVIDSON STREET & MAUNEY STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>118'</u>		<u>5.24</u>	<u>.96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>78'</u>			

ENTERS: 622 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION N. side of 622


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY GK

MAIN-SIZE 2 C.I. BARE STEEL COATED STEEL PLASTIC / YEAR INSTALLED 96

DEPTH: 3 FT. IN. LOCATION W. side of N. Highland

"A" P/S READING P TOTAL ANODES 1# 17# I.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>7</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY