

LOCATION 901 & 903 N Highland CITY GAST.

BETWEEN DAVIDSON STREET & No - OUT LET STREET

| | SIZE | TYPE | 903 LENGTH | 901 | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|------------|-----|-----------|---------|---------|
| MAIN TO BLDG. | 3/4" | P | 91' | 28' | | 7-10 | -96 |
| MAIN TO PROP. LINE | " | " | 35' | 0 | | | |
| PROP. LINE TO BLDG. | " | " | 56' | 28 | | | |

ENTERS: 903 BRANCHED INTO: 901

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION S. of 903
E. of 901


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY GK

MAIN-SIZE 2 C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 96

DEPTH: 3 FT. IN. LOCATION E. of N. Highland

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:



| Test Station | | |
|--|------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | P |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY