

LOCATION 920 N-Highland St CITY BARTONIA

BETWEEN Davidson STREET & Dead End. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>4'</u>	<u>11-26-97</u>	<u>Tied over</u>	<u>300' Existing</u>
MAIN TO PROP. LINE					<u>3/4 G.W. Pipe</u>	
PROP. LINE TO BLDG.						

ENTERS: 920 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 335' N of C of Davidson St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 4 FT. 0 IN. LOCATION 15' E of C of N-Highland St

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>1.1</u>

ENG. DEPT. USE ONLY

